



Permit
Discharge Monitoring Report

POKSF
11.3.18.1
V3

of following month to:
Oregon DEQ

Legal Name: Kinder Morgan Energy Partners, LP

Site/File ID #: Linnton/32300

Common Name: Kinder Morgan

County: Multnomah

Facility Location:

Month/Quarter/Year 9/3/01

11400 NW St. Helens Rd.
Portland, Or. 97231

Monitoring for Oil/Water Separator

TANK 3034

Day	Oil and Grease (mg/L)	Visible Sheen	Ethanol and/or MBTE	Flow
	Frequency varies, see permit	Daily, visual observation	Quarterly grab sample, if present on site and in bulk	Daily estimate, when discharging
Limit	10 mg/L monthly, 15 mg/L daily max.	No visible sheen at any time	No limit	No limit
1				
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12			<i>For July</i>	
13	<i>6.5</i>	<i>NONE</i>	<i>Exceeded ND</i>	
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				
29				
30				
31				
Total				<i>9/2/6</i>
Max.				
Average				<i>3040</i>

See Reverse Side for Additional Monitoring and Signature Block

USEPA SF



1288109

Stormwater Monitoring

Only for facilities required to have NPDES permits for stormwater, per 40 CFR 122.26
Monitoring required for each point identified in the Stormwater Pollution Control Plan

Day	Visible Sheen	Floating Solids (associated with industry)	Total Copper (mg/L)	Total Lead (mg/L)	Total Zinc (mg/L)	pH (S.U.)	Total Suspended Solids (mg/L)
	Daily when discharging, visual observation	Once per month when discharging	Twice per year, grab sample	Twice per year, grab sample	Twice per year, grab sample	Twice per year, grab sample	Twice per year, grab sample
Limit	No visible sheen	No visible discharge*	0.1 mg/L*	0.4 mg/L*	0.6 mg/L*	Within 6.0 to 9.0	130 mg/L*
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13						6.5	
14							
15							
16							
17							
18							
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
Total							
Max.							
Average							

*These are benchmarks, not effluent limits. If benchmarks are exceeded, review/possible revision of Stormwater plan is required. See permit for more details.

Signature Requirement

I certify, under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fines and imprisonment for knowing violations.

Signature of Responsible Official: Peter G. Murphy

Name and Title (Please Print): Peter G. Murphy Area Manager Portland

Date of Signature: 10-8-01 Telephone: 503-220-1254



CERTIFICATE OF ANALYSIS

ORIGINAL

CLIENT: KINDER-MORGAN WILLBRIDGE
5880 N.W. ST. HELENS RD.
PORTLAND OR 97210

PHONE: (503) 220-1260
FAX: (503) 220-1270

DATE SUBMITTED: 09/13/2001

PROJECT NAME: LINNTON T-3034 BATCH 01-05

CI SAMPLE	CLIENTS ID#	DATE	TIME	MATRIX	DESCRIPTION
11385-001		09/13/2001	1320	Water	Separator Water
11385-002		09/13/2001	1340	Water	Separator Water

REPORT DATE: 09/24/2001

REPORT NUMBER: 11385

PAGE: 1 OF

SAMPLE	ANALYSIS	PARAMETER	RESULTS	UNITS	DETECTION	ANALYST
					LIMIT	
Separator Water						
11385-001	O & G, TOTAL (HEM) EPA 1664	TOTAL OIL AND GREASE	6.5	mg/L	2	Gale S 09/13/2001
Separator Water						
11385-002	ALCOHOLS IN WATER EPA 8015M	METHANOL	NA	mg/L	5.	Dave M
		ETHANOL	ND	mg/L	5.	09/21/2001
		ISOPROPANOL	NA	mg/L	5.	
		t-BUTANOL	NA	mg/L	5.	
		n-PROPANOL	NA	mg/L	5.	
		SEC-BUTANOL	NA	mg/L	5.	
		ISOBUTANOL	NA	mg/L	5.	
		TERT-AMYL ALCOHOL	NA	mg/L	5.	
		n-BUTANOL	NA	mg/L	5.	

REVIEWED BY:

David Back - QS Manager

**TANK 3034
DISCHARGE REPORT**

NPDES Permit No. 1300-J

*Kinder Morgan
Linnton Terminal
11400 NW St. Helens Road
Portland, Oregon 97231*

Batch No.: 01-05

Start of Discharge:

Date	Start Time	Beginning Gauge Reading Gallons	Person Starting Discharge
9-26-01	0730	17'7 ⁷ / ₈ 43364	JB

End of Discharge:

Date	Ending Time	Ending Gauge Reading Gallons	Person Ending Discharge
9-26-01	1400	24'7 ⁷ / ₈ " 2148	JB

Total Gallons Discharged = 91,216

CHAIN OF CUSTODY RECORD AND NON-COMMERCIAL BILL OF LADING

Ph: (503) 286-9464 Fax: (503) 285-7831
Ph: (253) 922-8781 Fax: (253) 922-8957
Ph: (925) 229-0360 Fax: (925) 229-2821
Ph: (310) 833-1557 Fax: (310) 833-1585

Linton T-303
 Project Name: _____
 Project Number: NPDES-001
 P.O. Number: Batch 01-05
Testing Priority Notification Method(s)
☐ Normal ☐ Telephone
☐ Rush ☐ FAX
 Due Date _____ ☐ Mail

[illegible]

Relinquished By:	Date/Time	Received By:	Date/Time	<div style="text-align: center; border-bottom: 1px solid black; margin-bottom: 5px;">FOR LABORATORY USE ONLY</div> <div> Inspection Job Number: _____ PO # _____ </div> <div> Laboratory Project Number: _____ <input type="checkbox"/> Cash/Check # _____ </div> <div> Due Date: _____ Amount Paid: \$ _____ </div>
Relinquished By:	Date/Time	Received By:	Date/Time	